



25791 Commercentre Drive
Lake Forest, CA 92630

Telephone: (949)448-4100
Facsimile: (949)448-4111
www.intertek-etlsemko.com

07/29/2010

Letter Report No. 100154987LAX-001
Project No. G100154987

Mr. Neil Vitale
Luna US LLC
5795 S Sandhill Rd
Las Vegas, NV 89120

Ph. (702) 497-3872

Email: neil@lunaairforlife.com

Subject: ETL investigation of ballast for UVC lamp for air purification system; Models: LNT2-6000, LNIND14, LNIND9, LNT/MP 175, LNT/MP 250.

Dear Neil Vitale,

This letter concludes and represents the results of the evaluation and tests of the above referenced equipment to the requirements contained in the following standard:

- **UL 935**
Issue:2001/05/21 Ed:10 Rev:2006/02/20; Standard for Safety Fluorescent-Lamp Ballasts
- **CAN/CSA C22.2#74**
Issue:1996/01/01 Ed:4 (R2005) Equipment for Use with Electric Discharge Lamps

This investigation was authorized by signed application, dated 06/23/2010. New production line samples were provided on 06/11/10 and an evaluation and testing was performed from 07/20/2010 to 07/26/2010 at the Intertek's Lake Forest facility.

We are happy to inform you that the ballast for the UVC lamps comply with the requirements of the above referenced standards. All tests have been completed for the above referenced standards.

The following test was performed and complies with the standard requirements:

Test	UL 935	CAN/CSA-C22.2 #74	Verdict
Power Input Test	22	--	Pass
Normal Temperature Test	25	6.5	Pass
Abnormal Temperature Test	26	6.5.6	Pass
Dielectric Voltage-Withstand Test.	32	6.6	Pass
Leakage Current Test	23	6.7	Pass
Insulation-Resistance Test	33	--	Pass






This letter report completes our evaluation covered by Intertek Project No. G100154987. In responding to these items, please number your responses in accordance with the numbering in this letter report. Responding in this way assures that all responses are properly identified. Responses should be forwarded to your account representative, Ms. Anja Crotts to initiate a follow-up evaluation.

If there are any questions regarding the results contained in this report, or any of the other services offered by Intertek, please do not hesitate to contact the undersigned.

Please note; this Letter Report does not represent authorization for the use of any Intertek certification marks.

Completed by:	Ravi Sheth	Reviewed by:	Chandresh Thakur
Title:	Project Engineer	Title:	Engineering Manager
Signature:		Signature	
Date	07/29/2010	Date:	07/29/2010